



Model #	CBK
Serial #	
Kilowatts	20.00
Volts/Ph/Hz	208 / 3/ 60
Control Volts	24
Steps	2
Heater Amps	55.51
Heater Fuses	35/35
System Amps.	N/A
V.A.	15.0
Min. F.P.M.	810
Min. Wire Ga. CU	# 4 AWG
Control Wiring	---
Power Wiring	---
Other Wiring	---

NOTE :

- *Replace fuse links with G5-AM0400152C, use copper wire only suitable for at least 75° C
- ** Replace auto-reset with thermo disc type 60TX11-L145
- ***Replace manual-reset with thermo disc type 60TX11-L175
- FIELD WIRING, NEC Class I.

WARREN TECHNOLOGY	
Aprv. by DJG	RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram
Rev. by B.NGHIEM	MODEL EC12 20 KW 208/3
Date : 12/30/03	Dwg: RUP\EC\WEC12RP2003