



Model #	_____	CBK
Serial #	_____	
Kilowatts	_____	155.00
Volts/Ph/Hz	_____	460 / 3 Δ / 60
Control Volts	_____	24
Steps	_____	5
Heater Amps	_____	186.44
Heater Fuses	_____	50
System Amps.	_____	N/A
V.A.	_____	55.25
Min. F.P.M.	_____	1150
Min. Wire Ga. CU	_____	# 250 MCN
Control Wiring	_____	
Power Wiring	_____	
Other Wiring	_____	

NOTE :

- *Replace one shot therm-0-disc with L300F-61F14/L300F-60FXX14, use copper wire only suitable for at least 75 C°.
- ** Replace auto-reset with thermo disc type 60TX11-L145
- ***Replace manual-reset with thermo disc type 60TX11-L175
- FIELD WIRING, NEC Class I.

WARREN TECHNOLOGY

Aprv. by DJG	RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram
Rev. by B.NGIEM	MODEL EC4 155 KW 480/3
Date : 2/12/04	Dwg: RUP\EC\WEC4RP15505