



Model #	CBK
Serial #	
Kilowatts	36.00
Volts/Ph/Hz	208 / 3/ 60
Control Volts	24
Steps	3
Heater Amps	99.93
Heater Fuses	45
System Amps.	N/A
V.A.	27.0
Min. F.P.M.	780
Min. Wire Ga. CU	# 1 AWG
Control Wiring	-----
Power Wiring	-----
Other Wiring	-----

NOTE :  
 \*Replace one shot therm-D-disc with L300F-61F14/L300F-60FXX14, use copper wire only suitable for at least 75°C.  
 \*\* Replace auto-reset with thermo disc type 60TX11-L145  
 \*\*\*Replace manual-reset with thermo disc type 60TX11-L175  
 -FIELD WRING, NEC Class I.

<b>WARREN TECHNOLOGY</b>	
Aprv. by DJG	RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram
Rev. by B.NGHIEM	MODEL EC22 36 KW 208/3
Date : 12/30/03	Dwg: RUP\EC\WEC22RP3603