



IMPORTANT

Remove jumper between terminal I & C before connecting interlocks.
 Wire in accordance with local & Canadian Electrical codes. Read instructions carefully before wiring and operating.
 Frame shown in heavy line represents Thermolec Electric Coil. All wiring outside this frame are "typical external wiring by others".

LEGEND

- A Automatic reset thermal cut-out
- C1,C2 Control contactor
- SSR Solid State Relay
- D46 Step Controller
- DISC Disconnect switch
- F Fuse or fusible link
- H Heating element
- M Manual reset thermal cut-out
- PDS Pressure differential switch
- PES Pressure-electric switch
- T Control transformer