



- LEGEND**
- AC AUTOMATIC CUTOFF
  - MC MANUAL CUTOFF
  - DS DISCONNECT SWITCH
  - CONTACTOR COIL
  - HEATING ELEMENT
  - TR TRANSFORMER
  - CONTACT NORMALLY OPEN
  - FUSE

**WARNING:**  
Disconnect all supplies before working on this duct heater

**IMPORTANT:**  
Wire in according with electrical codes  
Use copper wire for 90°C minimum

**NOTE:**  
All wiring outside this frame are wiring by others

National Environmental Products Ltd 400, Lebeau, Montreal (QC) H4N 1R8  
T: (514) 333-1433 F: 333-3163

PROPRIETARY INFORMATION: THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION & IT'S PROPERTY OF N.E.P. LTD. THIS DOCUMENT AND THE INFORMATION IT CONTAINS SHALL NOT BE DUPLICATED OR USED IN WHOLE OR IN PART WITHOUT THE EXPRESS WRITTEN CONSENT OF N.E.P. LTD.

ELECTRICAL DRAWING

PART NUMBER: RTUEC-45KW2403  
PROJECT NAME: RTUEC  
CUSTOMER NAME: CAPTIVE AIRE, INC.